



8165 E Kaiser Blvd.
Anaheim, CA 92808
www.lightlaboratory.com

Report No: L042111905



Report No: L042111905

Issue Date: 4/23/2021

Report Prepared For: Hunter Industries
1940 Diamond St., San Marcos, CA 92078

Model Number: SL5ZDCCVFW

Test: Photometric/Colorimetric/Electrical Test

Standards Used: Appropriate part or all test guidelines were used for test performed:

IESNA LM79: 2008 Approved Methods for Electrical and Photometric Measurements of Solid-State Lighting Products

ANSI NEMA ANSLG C78.377: 2008 Specification of the Chromaticity of Solid State Lighting Products

ANSI C82.77:2002: Harmonic Emission Limits-Related Quality Requirements for Lighting Equipment

Description of Sample: Client submitted the sample. Received in working and undamaged condition. No modifications were necessary.

Special Test Condition: Fixture is tested using Controller(FXLuminaire LUXOR ZD LZD 150) with setting of Grp/Thm to Hue 43, Sat 50%, and Electricals are measured at fixture input.

Sample Arrival Date: 4/20/21

Date of Tests: 4/20/21 - 4/23/21

Seasoning of Sample: No seasoning was performed in accordance with IESNA LM-79.

Equipment List

| Equipment Used | Model No | Stock No | Calibration Due Date |
|-----------------------------------|------------|------------|----------------------|
| Chroma Programmable AC Source | 61604 | PS-AC02 | -- |
| Yokogawa Digital Power Meter | WT210 | MT-EL06-S4 | 4/7/23 |
| HP Power Supply | 6032A | PS-DC05-S2 | -- |
| Fluke Digital Thermometer | 52K/J | MT-TP05 | 3/17/23 |
| LLI Type C Goniophotometer System | RMG-C-MKII | CD-LL04-GC | -- |
| LLI 2M Sphere | 2MR97 | CD-SN03-S2 | -- |
| LLI Spectroradiometer | SPR-3000 | MT-SC01-S2 | Before Use |

General Information

| | |
|-----------------------------|-------------------|
| Manufacturer: | Hunter Industries |
| Model Number: | SL5ZDCCVFW |
| Driver Model Number: | N/A |

Test Summary

| | |
|--------------------------------------|--------|
| Total Lumens: | 166.00 |
| Efficacy: | 24.08 |
| Color Redering Index: | 56.5 |
| Correlated Color Temperature: | 2577 |
| Input Voltage (VAC/60Hz): | 14.44 |
| Input Current (Amp): | 0.5498 |
| Input Power (W): | 6.89 |
| Input Power Factor: | 0.8686 |
| Current ATHD (%): | 42.1% |

Test Condition

| | |
|--------------------------------------|------|
| Ambient Temperature (°C): | 25.0 |
| Stabilization Time (Hours): | 1:25 |
| Total Operating Time (Hours): | 2:25 |





FIG. 1 LUMINAIRE

Colorimetry Test Results

Spectral Power Distribution




CRI & CCT

| | |
|-----|----------|
| x | 0.4600 |
| y | 0.3953 |
| u' | 0.2697 |
| v' | 0.5214 |
| CRI | 56.50 |
| CCT | 2577 |
| Duv | -0.00571 |

R Values

| | |
|-----|--------|
| R1 | 50.31 |
| R2 | 81.14 |
| R3 | 77.06 |
| R4 | 37.24 |
| R5 | 47.97 |
| R6 | 69.87 |
| R7 | 68.07 |
| R8 | 20.37 |
| R9 | -48.61 |
| R10 | 60.94 |
| R11 | 16.97 |
| R12 | 54.40 |
| R13 | 55.79 |
| R14 | 83.96 |
| R15 | 46.81 |

CIE 1931 Chromaticity Diagram





8165 E Kaiser Blvd.
Anaheim, CA 92808
www.lightlaboratory.com

Report No: L042111905



Test Methods

Photometric Measurements - Goniophotometer

A Custom Light Laboratory Type C Rotating Mirror Goniophotometer was used to measure candelas(intensity) at each angle of distribution as defined by IESNA for the appropriate fixture type.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Spectral Measurements - Integrating Sphere

A Sensing Spectroradiometer SPR-3000, in conjunction with Light Laboratory 2 meter integrating sphere was used to measure chromaticity coordinates, correlated color temperature(CCT) and the color rendering index(CRI) for each sample.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Disclaimers:

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST or any agency of Federal Government.

Report Prepared by : Keyur Patel

Test Report Reviewed by:

Steve Kang
Quality Assurance

**Attached are photometric data reports. Total number of pages: 14*



8165 E. Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Photometric Test Report

IES ROAD REPORT

PHOTOMETRIC FILENAME : L042111905.IES

DESCRIPTIVE INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] L042111905
[TESTLAB] LIGHT LABORATORY, INC. (www.lightlaboratory.com)
[ISSUEDATE] 4/23/2021
[MANUFAC] Hunter Industries
[LUMCAT] SL5ZDCCVFW
[LUMINAIRE] SL5, ZDC, Curved, Flat White
[BALLASTCAT] N/A
[OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
[MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
[TEST CONDITION] Fixture is tested using Controller(FXLuminaire LUXOR ZD LZD 150) with setting of Grp/Thm to ALL Lts,
[MORE] Hue 43, Sat 50%, and Electricals are measured at fixture input.
[INPUT] 14.44VAC, 6.89W
[TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

| | |
|---|--------------------------------|
| IES Classification | Type III |
| Longitudinal Classification | Very Short |
| Lumens Per Lamp | N.A. (absolute) |
| Total Lamp Lumens | N.A. (absolute) |
| Luminaire Lumens | 166 |
| Downward Total Efficiency | N.A. (absolute) |
| Total Luminaire Efficiency | N.A. (absolute) |
| Luminaire Efficacy Rating (LER) | 24 |
| Total Luminaire Watts | 6.89 |
| Ballast Factor | 1.00 |
| Upward Waste Light Ratio | 0.06 |
| Maximum Candela | 107.51 |
| Maximum Candela Angle | 0H 42.5V |
| Maximum Candela (<90 Degrees Vertical) | 107.51 |
| Maximum Candela Angle (<90 Degrees Vertical) | 0H 42.5V |
| Maximum Candela At 90 Degrees Vertical | 13.03 (7.8% Luminaire Lumens) |
| Maximum Candela from 80 to <90 Degrees Vertical | 17.32 (10.4% Luminaire Lumens) |
| Cutoff Classification (deprecated) | N.A. (absolute) |

IES ROAD REPORT
PHOTOMETRIC FILENAME : L042111905.IES

LUMINAIRE CLASSIFICATION SYSTEM (LCS)

| | Lumens | % Lamp | % Luminaire |
|-------------------------------|----------|--------|-------------|
| FL - Front-Low (0-30) | 21.2 | N.A. | 12.8 |
| FM - Front-Medium (30-60) | 80.5 | N.A. | 48.5 |
| FH - Front-High (60-80) | 32.1 | N.A. | 19.4 |
| FVH - Front-Very High (80-90) | 5.4 | N.A. | 3.3 |
| BL - Back-Low (0-30) | 8.4 | N.A. | 5.0 |
| BM - Back-Medium (30-60) | 6.7 | N.A. | 4.0 |
| BH - Back-High (60-80) | 1.6 | N.A. | 1.0 |
| BVH - Back-Very High (80-90) | 0.3 | N.A. | 0.2 |
| UL - Uplight-Low (90-100) | 3.7 | N.A. | 2.2 |
| UH - Uplight-High (100-180) | 6.1 | N.A. | 3.7 |
| Total | 166.0 | N.A. | 100.0 |
| BUG Rating | B0-U1-G0 | | |

ZONAL LUMEN SUMMARY

| Zone | % |
|---------|------|
| 0-20 | 7.5 |
| 0-30 | 17.8 |
| 0-40 | 32.8 |
| 0-60 | 70.3 |
| 0-80 | 90.6 |
| 0-90 | 94.1 |
| 10-90 | 92.3 |
| 20-40 | 25.3 |
| 20-50 | 44 |
| 40-70 | 51.5 |
| 60-80 | 20.3 |
| 70-80 | 6.4 |
| 80-90 | 3.4 |
| 90-110 | 3.6 |
| 90-120 | 4.6 |
| 90-130 | 5.2 |
| 90-150 | 5.9 |
| 90-180 | 5.9 |
| 110-180 | 2.3 |
| 0-180 | 100 |

IES ROAD REPORT
PHOTOMETRIC FILENAME : L042111905.IES

CANDELA TABULATION

| Vert. Angles | Horizontal Angles | | | | | | | | | |
|-------------------------|--------------------------|-----------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| | <u>0</u> | <u>5</u> | <u>10</u> | <u>15</u> | <u>20</u> | <u>25</u> | <u>30</u> | <u>35</u> | <u>40</u> | <u>45</u> |
| 0.0 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 |
| 5.0 | 35.38 | 35.37 | 35.26 | 35.16 | 35.03 | 34.86 | 34.65 | 34.39 | 34.14 | 33.78 |
| 10.0 | 42.58 | 42.54 | 42.37 | 42.07 | 41.62 | 41.13 | 40.50 | 39.75 | 38.98 | 38.12 |
| 15.0 | 51.83 | 51.73 | 51.45 | 50.96 | 50.28 | 49.46 | 48.32 | 47.01 | 45.56 | 43.82 |
| 20.0 | 64.55 | 64.41 | 63.88 | 63.05 | 61.91 | 60.08 | 58.30 | 55.96 | 53.39 | 51.00 |
| 25.0 | 76.74 | 76.58 | 76.09 | 75.10 | 74.29 | 71.11 | 69.59 | 67.17 | 63.95 | 60.36 |
| 30.0 | 87.15 | 86.92 | 86.06 | 84.88 | 83.27 | 80.91 | 78.62 | 73.02 | 71.43 | 67.97 |
| 35.0 | 98.29 | 97.92 | 96.93 | 94.95 | 92.68 | 89.96 | 86.22 | 82.73 | 77.14 | 72.70 |
| 37.5 | 103.11 | 102.72 | 101.64 | 99.70 | 96.93 | 93.61 | 90.10 | 85.82 | 81.00 | 73.40 |
| 40.0 | 106.57 | 106.25 | 105.03 | 103.23 | 100.72 | 96.87 | 93.08 | 88.40 | 83.55 | 74.55 |
| 42.5 | 107.51 | 107.18 | 106.43 | 104.85 | 102.48 | 99.04 | 95.28 | 90.50 | 85.24 | 75.34 |
| 45.0 | 104.71 | 104.63 | 104.33 | 103.35 | 101.87 | 99.55 | 95.63 | 91.48 | 86.26 | 79.24 |
| 47.5 | 99.23 | 99.35 | 99.44 | 99.34 | 98.60 | 97.07 | 94.64 | 90.81 | 85.68 | 78.49 |
| 50.0 | 93.26 | 93.36 | 93.70 | 93.90 | 93.78 | 92.91 | 91.27 | 88.33 | 84.49 | 77.92 |
| 52.5 | 88.47 | 88.56 | 88.91 | 89.07 | 89.00 | 88.21 | 86.83 | 84.46 | 81.37 | 74.12 |
| 55.0 | 84.98 | 85.10 | 85.38 | 85.56 | 85.24 | 84.37 | 82.47 | 80.21 | 76.34 | 72.55 |
| 57.5 | 80.72 | 80.98 | 81.42 | 81.98 | 81.84 | 81.12 | 79.53 | 74.85 | 72.90 | 69.30 |
| 60.0 | 72.90 | 73.30 | 74.52 | 75.72 | 76.63 | 77.00 | 74.17 | 73.44 | 69.91 | 65.84 |
| 62.5 | 57.25 | 58.03 | 59.97 | 62.87 | 65.72 | 67.69 | 68.55 | 67.71 | 66.28 | 62.75 |
| 65.0 | 40.76 | 41.25 | 42.61 | 45.42 | 48.69 | 52.53 | 56.83 | 59.05 | 59.57 | 58.07 |
| 67.5 | 29.48 | 29.58 | 30.16 | 31.00 | 32.47 | 34.98 | 38.47 | 43.64 | 48.59 | 50.47 |
| 70.0 | 23.86 | 23.87 | 24.01 | 24.29 | 24.71 | 25.34 | 26.37 | 28.31 | 32.15 | 37.79 |
| 72.5 | 21.06 | 21.05 | 21.03 | 20.96 | 20.96 | 21.05 | 21.20 | 21.57 | 22.39 | 24.40 |
| 75.0 | 19.56 | 19.49 | 19.33 | 19.16 | 18.91 | 18.62 | 18.37 | 18.16 | 18.09 | 18.20 |
| 77.5 | 18.34 | 18.30 | 18.15 | 17.85 | 17.53 | 17.12 | 16.61 | 16.14 | 15.61 | 15.14 |
| 80.0 | 17.32 | 17.29 | 17.13 | 16.87 | 16.49 | 15.95 | 15.39 | 14.72 | 13.97 | 13.24 |
| 85.0 | 15.40 | 15.37 | 15.19 | 14.93 | 14.50 | 14.01 | 13.33 | 12.64 | 11.81 | 10.92 |
| 90.0 | 13.03 | 12.99 | 12.85 | 12.57 | 12.17 | 11.68 | 11.14 | 10.41 | 9.69 | 8.79 |
| 95.0 | 10.16 | 10.11 | 9.97 | 9.76 | 9.47 | 8.99 | 8.56 | 7.98 | 7.39 | 6.72 |
| 100.0 | 9.12 | 9.06 | 8.98 | 8.77 | 8.37 | 7.88 | 7.20 | 6.60 | 5.96 | 5.33 |
| 105.0 | 6.99 | 6.95 | 6.86 | 6.67 | 6.41 | 6.10 | 5.71 | 5.26 | 4.72 | 4.16 |
| 110.0 | 5.73 | 5.68 | 5.57 | 5.43 | 5.21 | 4.87 | 4.54 | 4.12 | 3.65 | 3.11 |
| 115.0 | 4.54 | 4.51 | 4.44 | 4.28 | 4.07 | 3.81 | 3.53 | 3.16 | 2.73 | 2.34 |
| 120.0 | 3.56 | 3.55 | 3.48 | 3.32 | 3.13 | 2.93 | 2.67 | 2.39 | 2.06 | 1.73 |
| 125.0 | 2.66 | 2.66 | 2.59 | 2.48 | 2.36 | 2.13 | 1.96 | 1.71 | 1.47 | 1.22 |
| 130.0 | 1.96 | 1.92 | 1.89 | 1.80 | 1.68 | 1.54 | 1.38 | 1.21 | 1.03 | 0.86 |
| 135.0 | 1.33 | 1.31 | 1.28 | 1.21 | 1.12 | 1.03 | 0.93 | 0.80 | 0.72 | 0.59 |
| 140.0 | 0.84 | 0.86 | 0.80 | 0.79 | 0.73 | 0.66 | 0.59 | 0.54 | 0.47 | 0.49 |
| 145.0 | 0.49 | 0.47 | 0.47 | 0.44 | 0.40 | 0.40 | 0.42 | 0.44 | 0.45 | 0.47 |
| 150.0 | 0.35 | 0.37 | 0.37 | 0.37 | 0.38 | 0.42 | 0.42 | 0.44 | 0.47 | 0.51 |
| 155.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 160.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 165.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 170.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 175.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 180.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

| Vert. Angles | Horizontal Angles | | | | | | | | | |
|-------------------------|--------------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|------------------|
| | <u>50</u> | <u>55</u> | <u>60</u> | <u>65</u> | <u>70</u> | <u>75</u> | <u>80</u> | <u>85</u> | <u>90</u> | <u>95</u> |
| 0.0 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 |
| 5.0 | 33.50 | 33.18 | 32.85 | 32.54 | 32.12 | 31.79 | 31.47 | 31.14 | 30.84 | 30.53 |
| 10.0 | 37.27 | 36.36 | 35.44 | 34.54 | 33.78 | 32.92 | 32.13 | 31.47 | 30.79 | 30.04 |

IES ROAD REPORT
PHOTOMETRIC FILENAME : L042111905.IES

CANDELA TABULATION - (Cont.)

| | | | | | | | | | | |
|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| 15.0 | 42.28 | 40.55 | 38.81 | 37.11 | 35.68 | 34.23 | 32.90 | 31.79 | 30.65 | 29.43 |
| 20.0 | 48.74 | 46.09 | 43.38 | 40.90 | 38.07 | 35.92 | 33.97 | 31.94 | 30.46 | 28.75 |
| 25.0 | 56.04 | 52.53 | 49.20 | 45.20 | 41.88 | 38.74 | 35.33 | 32.89 | 30.56 | 27.33 |
| 30.0 | 63.92 | 58.91 | 53.83 | 49.48 | 44.59 | 40.62 | 36.92 | 32.96 | 30.13 | 26.79 |
| 35.0 | 68.95 | 64.37 | 59.22 | 52.65 | 47.59 | 42.98 | 37.67 | 33.57 | 29.51 | 24.90 |
| 37.5 | 71.25 | 66.19 | 60.58 | 54.79 | 48.71 | 43.19 | 38.49 | 33.58 | 29.08 | 24.08 |
| 40.0 | 72.23 | 67.45 | 61.75 | 56.10 | 49.00 | 43.63 | 38.70 | 33.06 | 28.61 | 23.58 |
| 42.5 | 72.90 | 68.36 | 62.68 | 57.04 | 50.28 | 43.89 | 38.25 | 33.32 | 27.93 | 21.90 |
| 45.0 | 73.18 | 69.00 | 63.71 | 57.00 | 50.84 | 44.64 | 38.02 | 32.90 | 27.33 | 20.85 |
| 47.5 | 73.26 | 68.97 | 63.05 | 57.63 | 50.93 | 43.94 | 38.11 | 32.27 | 26.39 | 19.82 |
| 50.0 | 72.62 | 68.60 | 62.70 | 57.18 | 50.07 | 43.54 | 37.41 | 30.88 | 25.24 | 18.91 |
| 52.5 | 72.16 | 67.62 | 61.98 | 56.44 | 50.09 | 42.94 | 35.85 | 30.25 | 23.84 | 16.92 |
| 55.0 | 69.40 | 65.46 | 60.95 | 54.79 | 49.04 | 42.70 | 34.68 | 28.76 | 22.53 | 16.36 |
| 57.5 | 66.12 | 62.49 | 58.37 | 53.70 | 47.59 | 40.74 | 33.95 | 27.14 | 20.70 | 15.89 |
| 60.0 | 62.42 | 58.87 | 55.36 | 51.43 | 45.28 | 39.16 | 32.34 | 24.59 | 18.62 | 12.42 |
| 62.5 | 58.91 | 55.08 | 51.78 | 48.52 | 43.61 | 37.13 | 29.72 | 23.05 | 16.36 | 10.53 |
| 65.0 | 54.40 | 50.91 | 47.61 | 43.91 | 40.06 | 34.68 | 26.93 | 20.15 | 13.59 | 8.93 |
| 67.5 | 49.86 | 47.03 | 43.31 | 39.87 | 35.75 | 30.56 | 24.61 | 16.35 | 10.79 | 7.58 |
| 70.0 | 41.57 | 41.95 | 39.49 | 35.61 | 31.56 | 26.34 | 19.98 | 13.47 | 8.21 | 6.41 |
| 72.5 | 28.73 | 33.53 | 34.28 | 31.63 | 27.72 | 22.39 | 15.67 | 9.52 | 6.03 | 5.38 |
| 75.0 | 18.77 | 21.32 | 25.52 | 26.11 | 23.52 | 17.62 | 10.78 | 6.24 | 4.86 | 4.40 |
| 77.5 | 14.78 | 14.64 | 15.19 | 17.17 | 16.80 | 11.42 | 6.55 | 4.68 | 3.81 | 3.21 |
| 80.0 | 12.57 | 11.82 | 11.11 | 10.64 | 9.33 | 6.79 | 4.68 | 3.44 | 2.83 | 2.20 |
| 85.0 | 9.87 | 8.87 | 7.82 | 6.50 | 5.20 | 3.67 | 2.52 | 1.80 | 1.14 | 0.58 |
| 90.0 | 7.95 | 6.92 | 5.85 | 4.73 | 3.67 | 2.52 | 1.59 | 0.93 | 0.49 | 0.45 |
| 95.0 | 6.13 | 5.40 | 4.52 | 3.48 | 2.41 | 1.62 | 1.00 | 0.61 | 0.47 | 0.45 |
| 100.0 | 4.56 | 3.88 | 3.11 | 2.32 | 1.66 | 1.08 | 0.73 | 0.56 | 0.47 | 0.47 |
| 105.0 | 3.51 | 2.88 | 2.22 | 1.62 | 1.17 | 0.84 | 0.63 | 0.54 | 0.51 | 0.49 |
| 110.0 | 2.64 | 2.06 | 1.61 | 1.22 | 0.86 | 0.68 | 0.59 | 0.56 | 0.54 | 0.56 |
| 115.0 | 1.94 | 1.54 | 1.19 | 0.87 | 0.68 | 0.61 | 0.59 | 0.59 | 0.59 | 0.61 |
| 120.0 | 1.38 | 1.12 | 0.87 | 0.68 | 0.61 | 0.59 | 0.61 | 0.61 | 0.63 | 0.65 |
| 125.0 | 1.01 | 0.79 | 0.65 | 0.58 | 0.59 | 0.59 | 0.63 | 0.65 | 0.66 | 0.68 |
| 130.0 | 0.73 | 0.59 | 0.56 | 0.58 | 0.59 | 0.61 | 0.65 | 0.66 | 0.68 | 0.72 |
| 135.0 | 0.51 | 0.52 | 0.56 | 0.58 | 0.61 | 0.65 | 0.66 | 0.68 | 0.70 | 0.73 |
| 140.0 | 0.51 | 0.52 | 0.56 | 0.58 | 0.61 | 0.65 | 0.68 | 0.70 | 0.73 | 0.75 |
| 145.0 | 0.52 | 0.54 | 0.58 | 0.59 | 0.63 | 0.65 | 0.68 | 0.70 | 0.73 | 0.75 |
| 150.0 | 0.54 | 0.54 | 0.58 | 0.59 | 0.63 | 0.65 | 0.68 | 0.70 | 0.73 | 0.77 |
| 155.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 160.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 165.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 170.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 175.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 180.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

Vert. Angles **Horizontal Angles**

| | <u>100</u> | <u>105</u> | <u>110</u> | <u>115</u> | <u>120</u> | <u>125</u> | <u>130</u> | <u>135</u> | <u>140</u> | <u>145</u> |
|------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| 0.0 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 |
| 5.0 | 30.18 | 29.86 | 29.53 | 29.06 | 28.57 | 28.10 | 27.56 | 27.05 | 26.60 | 26.21 |
| 10.0 | 29.29 | 28.28 | 27.07 | 25.99 | 24.94 | 24.21 | 23.58 | 23.07 | 22.81 | 22.69 |
| 15.0 | 28.01 | 26.23 | 24.57 | 23.47 | 22.72 | 22.41 | 22.65 | 23.30 | 23.87 | 24.00 |
| 20.0 | 26.20 | 24.07 | 22.63 | 22.01 | 22.55 | 23.04 | 22.88 | 22.15 | 21.29 | 20.15 |
| 25.0 | 24.59 | 22.09 | 21.53 | 22.06 | 22.01 | 20.68 | 19.18 | 17.27 | 15.23 | 13.45 |
| 30.0 | 22.84 | 21.29 | 21.55 | 21.10 | 19.18 | 16.91 | 15.56 | 10.74 | 8.14 | 6.08 |
| 35.0 | 21.22 | 20.31 | 19.96 | 17.95 | 15.53 | 10.27 | 7.13 | 4.04 | 1.68 | 0.61 |
| 37.5 | 20.12 | 19.67 | 18.60 | 16.17 | 13.94 | 7.70 | 3.88 | 1.54 | 0.54 | 0.40 |

IES ROAD REPORT
PHOTOMETRIC FILENAME : L042111905.IES

CANDELA TABULATION - (Cont.)

| | | | | | | | | | | |
|-------|-------|-------|-------|-------|------|------|------|------|------|------|
| 40.0 | 19.47 | 18.81 | 17.17 | 14.83 | 8.56 | 4.56 | 1.69 | 0.52 | 0.40 | 0.38 |
| 42.5 | 18.69 | 17.83 | 14.83 | 10.88 | 6.32 | 2.18 | 0.65 | 0.44 | 0.40 | 0.38 |
| 45.0 | 18.30 | 17.03 | 12.82 | 8.42 | 3.41 | 0.94 | 0.49 | 0.44 | 0.40 | 0.40 |
| 47.5 | 17.78 | 14.78 | 10.81 | 5.68 | 1.87 | 0.65 | 0.45 | 0.44 | 0.40 | 0.38 |
| 50.0 | 17.20 | 13.71 | 9.34 | 3.62 | 1.08 | 0.58 | 0.45 | 0.44 | 0.40 | 0.40 |
| 52.5 | 16.85 | 12.23 | 6.92 | 2.48 | 0.93 | 0.54 | 0.45 | 0.42 | 0.40 | 0.40 |
| 55.0 | 16.21 | 10.36 | 5.14 | 1.85 | 0.82 | 0.54 | 0.45 | 0.40 | 0.40 | 0.38 |
| 57.5 | 15.60 | 9.45 | 4.07 | 1.57 | 0.80 | 0.52 | 0.42 | 0.40 | 0.40 | 0.38 |
| 60.0 | 10.97 | 7.96 | 3.62 | 1.52 | 0.79 | 0.51 | 0.42 | 0.40 | 0.40 | 0.38 |
| 62.5 | 9.71 | 6.57 | 2.86 | 1.49 | 0.79 | 0.49 | 0.42 | 0.40 | 0.40 | 0.40 |
| 65.0 | 8.17 | 5.08 | 2.43 | 1.22 | 0.68 | 0.47 | 0.42 | 0.40 | 0.39 | 0.38 |
| 67.5 | 6.62 | 4.38 | 2.01 | 1.00 | 0.59 | 0.46 | 0.42 | 0.40 | 0.39 | 0.40 |
| 70.0 | 5.50 | 3.46 | 1.49 | 0.79 | 0.49 | 0.42 | 0.42 | 0.40 | 0.40 | 0.40 |
| 72.5 | 4.37 | 2.59 | 1.07 | 0.56 | 0.42 | 0.42 | 0.42 | 0.40 | 0.40 | 0.40 |
| 75.0 | 3.20 | 1.78 | 0.72 | 0.44 | 0.42 | 0.42 | 0.42 | 0.40 | 0.42 | 0.40 |
| 77.5 | 2.25 | 0.93 | 0.45 | 0.42 | 0.42 | 0.42 | 0.42 | 0.40 | 0.42 | 0.40 |
| 80.0 | 1.21 | 0.49 | 0.44 | 0.42 | 0.42 | 0.44 | 0.42 | 0.42 | 0.42 | 0.40 |
| 85.0 | 0.45 | 0.44 | 0.44 | 0.44 | 0.46 | 0.44 | 0.44 | 0.44 | 0.42 | 0.44 |
| 90.0 | 0.45 | 0.45 | 0.44 | 0.46 | 0.46 | 0.46 | 0.44 | 0.45 | 0.44 | 0.44 |
| 95.0 | 0.45 | 0.45 | 0.45 | 0.47 | 0.46 | 0.46 | 0.45 | 0.45 | 0.45 | 0.45 |
| 100.0 | 0.47 | 0.49 | 0.49 | 0.49 | 0.47 | 0.49 | 0.47 | 0.47 | 0.49 | 0.47 |
| 105.0 | 0.51 | 0.51 | 0.52 | 0.49 | 0.51 | 0.51 | 0.51 | 0.51 | 0.51 | 0.52 |
| 110.0 | 0.56 | 0.56 | 0.56 | 0.54 | 0.56 | 0.56 | 0.56 | 0.56 | 0.58 | 0.58 |
| 115.0 | 0.61 | 0.61 | 0.61 | 0.61 | 0.63 | 0.63 | 0.65 | 0.65 | 0.65 | 0.66 |
| 120.0 | 0.66 | 0.66 | 0.68 | 0.70 | 0.70 | 0.72 | 0.73 | 0.73 | 0.75 | 0.75 |
| 125.0 | 0.70 | 0.73 | 0.75 | 0.75 | 0.79 | 0.79 | 0.80 | 0.82 | 0.84 | 0.86 |
| 130.0 | 0.73 | 0.77 | 0.79 | 0.80 | 0.82 | 0.84 | 0.86 | 0.87 | 0.89 | 0.91 |
| 135.0 | 0.75 | 0.79 | 0.79 | 0.84 | 0.86 | 0.87 | 0.89 | 0.91 | 0.93 | 0.94 |
| 140.0 | 0.79 | 0.80 | 0.82 | 0.84 | 0.87 | 0.87 | 0.89 | 0.93 | 0.94 | 0.94 |
| 145.0 | 0.79 | 0.80 | 0.82 | 0.84 | 0.87 | 0.86 | 0.89 | 0.91 | 0.91 | 0.93 |
| 150.0 | 0.77 | 0.80 | 0.80 | 0.82 | 0.84 | 0.86 | 0.86 | 0.87 | 0.87 | 0.89 |
| 155.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 160.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 165.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 170.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 175.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 180.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

Vert. Horizontal Angles
Angles


| | 150 | 155 | 160 | 165 | 170 | 175 | 180 |
|------|------------|------------|------------|------------|------------|------------|------------|
| 0.0 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 | 30.84 |
| 5.0 | 25.93 | 25.71 | 25.52 | 25.36 | 25.27 | 25.20 | 25.18 |
| 10.0 | 22.63 | 22.62 | 22.67 | 22.81 | 22.93 | 23.04 | 23.05 |
| 15.0 | 23.66 | 23.33 | 23.05 | 22.77 | 22.62 | 22.51 | 22.46 |
| 20.0 | 19.16 | 18.11 | 17.20 | 16.45 | 15.95 | 15.60 | 15.51 |
| 25.0 | 11.65 | 10.13 | 8.86 | 7.98 | 7.23 | 6.86 | 6.71 |
| 30.0 | 4.16 | 2.55 | 1.36 | 0.66 | 0.51 | 0.49 | 0.45 |
| 35.0 | 0.42 | 0.37 | 0.35 | 0.35 | 0.35 | 0.37 | 0.35 |
| 37.5 | 0.37 | 0.37 | 0.35 | 0.37 | 0.35 | 0.37 | 0.35 |
| 40.0 | 0.37 | 0.37 | 0.37 | 0.37 | 0.35 | 0.37 | 0.35 |
| 42.5 | 0.37 | 0.37 | 0.37 | 0.37 | 0.35 | 0.37 | 0.35 |
| 45.0 | 0.37 | 0.38 | 0.37 | 0.37 | 0.37 | 0.37 | 0.35 |
| 47.5 | 0.38 | 0.38 | 0.37 | 0.37 | 0.37 | 0.37 | 0.35 |
| 50.0 | 0.38 | 0.38 | 0.37 | 0.37 | 0.37 | 0.37 | 0.35 |
| 52.5 | 0.37 | 0.38 | 0.37 | 0.37 | 0.37 | 0.37 | 0.38 |

IES ROAD REPORT
PHOTOMETRIC FILENAME : L042111905.IES

CANDELA TABULATION - (Cont.)

| | | | | | | | |
|-------|------|------|------|------|------|------|------|
| 55.0 | 0.38 | 0.38 | 0.37 | 0.38 | 0.38 | 0.37 | 0.38 |
| 57.5 | 0.38 | 0.38 | 0.37 | 0.38 | 0.37 | 0.38 | 0.38 |
| 60.0 | 0.38 | 0.38 | 0.37 | 0.38 | 0.38 | 0.37 | 0.38 |
| 62.5 | 0.38 | 0.38 | 0.37 | 0.38 | 0.38 | 0.38 | 0.38 |
| 65.0 | 0.38 | 0.38 | 0.40 | 0.38 | 0.38 | 0.38 | 0.38 |
| 67.5 | 0.38 | 0.38 | 0.38 | 0.38 | 0.38 | 0.40 | 0.38 |
| 70.0 | 0.38 | 0.38 | 0.38 | 0.38 | 0.38 | 0.40 | 0.38 |
| 72.5 | 0.40 | 0.40 | 0.40 | 0.38 | 0.40 | 0.40 | 0.38 |
| 75.0 | 0.38 | 0.40 | 0.40 | 0.40 | 0.40 | 0.40 | 0.38 |
| 77.5 | 0.38 | 0.40 | 0.40 | 0.38 | 0.40 | 0.40 | 0.38 |
| 80.0 | 0.42 | 0.40 | 0.40 | 0.42 | 0.40 | 0.40 | 0.42 |
| 85.0 | 0.42 | 0.42 | 0.42 | 0.42 | 0.42 | 0.42 | 0.42 |
| 90.0 | 0.44 | 0.44 | 0.44 | 0.44 | 0.44 | 0.44 | 0.42 |
| 95.0 | 0.45 | 0.45 | 0.45 | 0.45 | 0.45 | 0.44 | 0.45 |
| 100.0 | 0.49 | 0.47 | 0.47 | 0.45 | 0.45 | 0.47 | 0.45 |
| 105.0 | 0.51 | 0.51 | 0.51 | 0.51 | 0.49 | 0.47 | 0.49 |
| 110.0 | 0.58 | 0.56 | 0.56 | 0.56 | 0.54 | 0.54 | 0.52 |
| 115.0 | 0.68 | 0.66 | 0.66 | 0.65 | 0.66 | 0.65 | 0.66 |
| 120.0 | 0.77 | 0.79 | 0.79 | 0.80 | 0.80 | 0.80 | 0.80 |
| 125.0 | 0.87 | 0.87 | 0.91 | 0.91 | 0.93 | 0.94 | 0.94 |
| 130.0 | 0.94 | 0.96 | 0.98 | 0.98 | 1.00 | 1.01 | 1.01 |
| 135.0 | 0.98 | 1.00 | 1.01 | 1.03 | 1.03 | 1.01 | 1.05 |
| 140.0 | 0.98 | 1.00 | 1.01 | 1.01 | 1.03 | 1.03 | 1.05 |
| 145.0 | 0.96 | 0.96 | 0.98 | 0.98 | 0.98 | 1.00 | 0.98 |
| 150.0 | 0.89 | 0.91 | 0.91 | 0.93 | 0.91 | 0.93 | 0.91 |
| 155.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 160.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 165.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 170.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 175.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 180.0 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |


COEFFICIENTS OF UTILIZATION



FLUX DISTRIBUTION

| | Lumens | Percent Of Luminaire |
|----------------------|--------|-------------------------|
| Downward Street Side | 139.3 | 83.9 |
| Downward House Side | 16.9 | 10.2 |
| Downward Total | 156.2 | 94.1 |
| Upward Street Side | 7.9 | 4.8 |
| Upward House Side | 1.9 | 1.1 |
| Upward Total | 9.8 | 5.9 |
| Total Flux | 166.0 | 100.0 |

POLAR GRAPH




Maximum Candela = 107.51 Located At Horizontal Angle = 0, Vertical Angle = 42.5


1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)

2 - Horizontal Cone Through Vertical Angle (42.5) (Through Max. Cd.)

ISOFOOTCANDLE LINES OF HORIZONTAL ILLUMINANCE



LUMINAIRE CLASSIFICATION SYSTEM (LCS) GRAPH



Luminaire Lumens:
Front: Low=21.2, Medium=80.5, High=32.1, Very High=5.4
Back: Low=8.4, Medium=6.7, High=1.6, Very High=0.3
Uplight: Low=3.7, High=6.1

BUG Rating : B0-U1-G0